

Belmont County



Ohio Public Water System Fluoride Levels, 2012

<u>PWS ID</u>	<u>Water System</u>	<u>Population Served</u>	<u>Fluoridation Status</u>	<u>Fluoride Level</u>	<u>Purchase From ID</u>	<u>Purchase From Name</u>
OH0700011	Barnesville	6,500	Adjusted			
OH0700114	Bellaire Public Water System	6,549	Adjusted			
OH0700315	Belmont Public Water System	532	Deficient	0.38		
OH0700412	Belmont Co. Sanitary District 3 PWS	24,387	Adjusted			
OH0700511	Bethesda Public Water System	1,413	Purchase		OH0700011	Barnesville Public Water System
OH0700612	Bridgeport Public Water System	2,830	Adjusted			
OH0700912	Flushing Village PWS	1,803	Purchase		OH0700412	Belmont Co. Sanitary District 3 PWS
OH0701112	Holloway Public Water System	345	Deficient	0.23		
OH0701212	Martins Ferry Public Water System	9,330	Adjusted			
OH0701303	Morristown Public Water System	299	Purchase		OH0700412	Belmont Co. Sanitary District 3 PWS
OH0701412	Powhatan Point Public Water System	1,807	Adjusted			
OH0701516	St. Clairsville City PWS	5,057	Adjusted			
OH0701612	Shadyside Public Water System	3,812	Adjusted			
OH0701703	York Township Water Authority PWS	481	Purchase		OH0701412	Powhatan Point Public Water System
OH0701803	Belmont Co. Sewer District 1B PWS	1,379	Purchase		OH0700612	Bridgeport Public Water System

How to use this table:

Adjusted: The natural fluoride level is adjusted to the optimum level for good dental health. [Click](#) for information about optimum fluoride levels.

Deficient: The natural fluoride level is below the optimum level for good dental health.

Natural: The fluoride level is naturally at optimum or higher levels.

Purchase: The water system purchases optimally fluoridated water from another public water system.

Fluoride Level: The fluoride level is provided for systems that do not adjust or purchase. Fluoride concentration is measured in parts per million (ppm) or milligrams per liter (mg/L).

Purchase From: The PWS ID indicated can be traced back to the original source of purchased water. The first two letters identify the state. The first two digits of the PWS ID identify the county in alphabetical order ([click](#) for a list of Ohio counties by code). The last five digits identify the system.

Belmont County



Ohio Public Water System Fluoride Levels, 2012

Please Note:

*Some water systems have fluoride levels tested at commercial labs that report levels of fluoride that are less than 0.5 ppm as "<0.5ppm." This is NOT specific enough for purposes of prescribing fluoride supplements. Health professionals should contact their local water plant in order to obtain more specific information on low fluoride levels.

**Public water systems comprise only a proportion of water systems that serve a county population. Some areas are served by non-community water systems.

The fluoride levels in the drinking water provided by public water systems which do not add supplemental fluoride are assumed to be the same as the natural fluoride content of the source water since typical water treatment or storage processes are not expected to remove fluoride.