

# Butler County

## Ohio Public Water System Fluoride Levels, 2012



<u>PWS ID</u>	<u>Water System</u>	<u>Population Served</u>	<u>Fluoridation Status</u>	<u>Fluoride Level</u>	<u>Purchase From ID</u>	<u>Purchase From Name</u>
OH0900303	Butler Co. Water District 2 PWS	105,915	Purchase		OH0904012	Hamilton Public Water System
OH0900512	Catalina Mobile Home Park	1,280	Deficient	<0.50		
OH0900612	Edgewood Mobile Home Park	30	Deficient	<0.20		
OH0900715	Fairfield City PWS	42,097	Adjusted			
OH0901412	Linda Mobile Home Park PWS	250	Deficient	<0.50		
OH0901712	Middletown City PWS	51,848	Adjusted			
OH0902012	Monroe City PWS	12,246	Adjusted			
OH0902112	New Miami Village PWS	3,220	Adjusted			
OH0902312	Oxford City PWS	22,500	Adjusted			
OH0902512	Ross Meadows	60	Natural	1.18		
OH0902612	Seven Mile Village PWS	900	Purchase		OH0903912	Swr Water District PWS
OH0902912	Crouse Mobile Home Park	267	Deficient	<0.20		
OH0903012	Trenton City PWS	11,000	Adjusted			
OH0903503	New London 1 PWS	335	Purchase		OH0903912	Swr Water District PWS
OH0903912	Swr Water District PWS	50,176	Adjusted			
OH0904012	Hamilton Public Water System	61,000	Adjusted			

### How to use this table:

Fluoridation Status: **Adjusted:** The natural fluoride level is adjusted to the optimum level for good dental health. [Click](#) for information about optimum fluoride levels.  
**Deficient:** The natural fluoride level is below the optimum level for good dental health.  
**Natural:** The fluoride level is naturally at optimum or higher levels.  
**Purchase:** The water system purchases optimally fluoridated water from another public water system.

Fluoride Level: The fluoride level is provided for systems that do not adjust or purchase. Fluoride concentration is measured in parts per million (ppm) or milligrams per liter (mg/L).

Purchase From: The PWS ID indicated can be traced back to the original source of purchased water. The first two letters identify the state. The first two digits of the PWS ID identify the county in alphabetical order ([click](#) for a list of Ohio counties by code). The last five digits identify the system.

# Butler County

---



## Ohio Public Water System Fluoride Levels, 2012

**Please Note:**

\*Some water systems have fluoride levels tested at commercial labs that report levels of fluoride that are less than 0.5 ppm as "<0.5ppm." This is NOT specific enough for purposes of prescribing fluoride supplements. Health professionals should contact their local water plant in order to obtain more specific information on low fluoride levels.

\*\*Public water systems comprise only a proportion of water systems that serve a county population. Some areas are served by non-community water systems.

*The fluoride levels in the drinking water provided by public water systems which do not add supplemental fluoride are assumed to be the same as the natural fluoride content of the source water since typical water treatment or storage processes are not expected to remove fluoride.*