

Fairfield County

Ohio Public Water System Fluoride Levels, 2012



<u>PWS ID</u>	<u>Water System</u>	<u>Population Served</u>	<u>Fluoridation Status</u>	<u>Fluoride Level</u>	<u>Purchase From ID</u>	<u>Purchase From Name</u>
OH2300012	Amanda Village PWS	800	Deficient	<0.50		
OH2300112	Baltimore Village PWS	3,123	Natural	1.85		
OH2300212	Bremen Village	1,372	Deficient	<0.50		
OH2300312	Carroll Village PWS	488	Purchase		OH2303212	Little Walnut Water Treatment Facility P
OH2300512	Colony Village MHP	89	Deficient	<0.20		
OH2300712	Heartland/Fairfield Care	158	Deficient	0.28		
OH2301012	Lancaster City PWS	37,160	Deficient	0.26		
OH2301112	Lithopolis Village PWS	1,100	Deficient	0.33		
OH2301212	Millersport Village PWS^	3,620	Natural	0.46		
OH2301412	Odc-Southeastern Correctional Institute	1,500	Deficient	<0.20		
OH2301512	Pickerington City PWS	17,000	Adjusted			
OH2301712	Pleasantville Village PWS	877	Deficient	<0.50		
OH2301812	Greenfield Twp Water District	870	Deficient	0.29		
OH2301912	Fairfield County Utilities PWS	15,285	Adjusted			
OH2302012	Brookdale Mobile Home Park	68	Deficient	<0.20		
OH2302112	Sugar Grove Village PWS	465	Deficient	<0.50		
OH2302212	Buckeye Beach Marina MHP	140	Deficient	0.28		
OH2302312	Valley View Nursing Home	60	Deficient	0.25		
OH2302712	Hillview Mobile Village	30	Deficient	<0.50		
OH2302812	Rustic Ridge MHP	438	Deficient	<0.20		
OH2302903	Thurston Village PWS	555	Purchase		OH2300112	Baltimore Village PWS
OH2303103	Rushville Village PWS	466	Deficient	0.50	OH2300212	Bremen Village
OH2303212	Little Walnut Water Treatment Facility	1,016	Adjusted			

^ Millersport Village ranges from 0.46 to 1.7, depending on which wells are being utilized

Fairfield County



Ohio Public Water System Fluoride Levels, 2012

How to use this table:

Fluoridation Status: **Adjusted:** The natural fluoride level is adjusted to the optimum level for good dental health. [Click](#) for information about optimum fluoride levels.
Deficient: The natural fluoride level is below the optimum level for good dental health.
Natural: The fluoride level is naturally at optimum or higher levels.
Purchase: The water system purchases optimally fluoridated water from another public water system.

Fluoride Level: The fluoride level is provided for systems that do not adjust or purchase. Fluoride concentration is measured in parts per million (ppm) or milligrams per liter (mg/L).

Purchase From: The PWS ID indicated can be traced back to the original source of purchased water. The first two letters identify the state. The first two digits of the PWS ID identify the county in alphabetical order ([click](#) for a list of Ohio counties by code). The last five digits identify the system.

Please Note:

*Some water systems have fluoride levels tested at commercial labs that report levels of fluoride that are less than 0.5 ppm as "<0.5ppm." This is NOT specific enough for purposes of prescribing fluoride supplements. Health professionals should contact their local water plant in order to obtain more specific information on low fluoride levels.

**Public water systems comprise only a proportion of water systems that serve a county population. Some areas are served by non-community water systems.

The fluoride levels in the drinking water provided by public water systems which do not add supplemental fluoride are assumed to be the same as the natural fluoride content of the source water since typical water treatment or storage processes are not expected to remove fluoride.