

Geauga County

Ohio Public Water System Fluoride Levels, 2012



<u>PWS ID</u>	<u>Water System</u>	<u>Population Served</u>	<u>Fluoridation Status</u>	<u>Fluoride Level</u>	<u>Purchase From ID</u>	<u>Purchase From Name</u>
OH2800012	Beaver Creek Estates	46	Deficient	<0.50		
OH2800112	Fox Hill Water Company	60	Deficient	<0.50		
OH2800212	Blossom Hill Care Center	86	Deficient	0.52		
OH2800312	Burton Village PWS	1,349	Deficient	<0.20		
OH2800412	Chardon City PWS	5,100	Adjusted			
OH2800612	Deer Lake Mobile Park	40	Deficient	0.18		
OH2801112	Big Creek Properties	130	Deficient	<0.20		
OH2801312	Holly Hill Nursing Home	106	Deficient	<0.20		
OH2801412	Jacques MHP Lp	300	Deficient	<0.20		
OH2801512	Lake Lucerne Club Co.	980	Natural	0.96		
OH2801612	Leaders MHP PWS	700	Deficient	<0.50		
OH2801712	Manchester Farms Water	89	Deficient	<0.50		
OH2801812	Maywood Community Inc.	150	Deficient	<0.50		
OH2801912	Middlefield Mobile Home Park	350	Natural	0.95		
OH2802012	Middlefield Village PWS	2,300	Deficient	<0.50		
OH2802112	Rustic Pines MHP	275	Deficient	0.13		
OH2802211	Paw Paw Lake	120	Deficient	<0.10		
OH2802412	Notre Dame Sisters And Elementary School	680	Deficient	0.14		
OH2802512	Tanglewood Lake Water Co	1,800	Adjusted			
OH2802612	Terrace Glen Estates	217	Deficient	<0.50		
OH2802712	Troy Oaks Homes	450	Deficient	0.24		
OH2803012	Wilders Mobile Home Park PWS	223	Deficient	<0.50		
OH2803112	Bainbrook Water Company PWS	350	Deficient	0.12		

Geauga County



Ohio Public Water System Fluoride Levels, 2012

<u>PWS ID</u>	<u>Water System</u>	<u>Population Served</u>	<u>Fluoridation Status</u>	<u>Fluoride Level</u>	<u>Purchase From ID</u>	<u>Purchase From Name</u>
OH2803212	The Trees Condominium	50	Deficient	<0.50		
OH2803312	Kimberly Estates	288	Deficient	<0.50		
OH2803512	Whitetail Run Homeowners	250	Deficient	<0.50		
OH2803612	Aqua Ohio - Auburn Lakes PWS	290	Deficient	0.14		
OH2803712	Scranton Woods	114	Deficient	0.34		
OH2803812	Metzenbaum Residence	64	Deficient	<0.50		
OH2804003	Geauga County-Bainbridge	2,500	Purchase		OH1801212	Cleveland Public Water System
OH2804112	Laurel Springs Water Co.	448	Deficient	<0.10		
OH2804212	Heather Hill Care Communities	450	Deficient	<0.50		
OH2868112	Geauga County Services Center PWS	600	Deficient	<0.20		

How to use this table:

Fluoridation Status: **Adjusted:** The natural fluoride level is adjusted to the optimum level for good dental health. [Click](#) for information about optimum fluoride levels.
Deficient: The natural fluoride level is below the optimum level for good dental health.
Natural: The fluoride level is naturally at optimum or higher levels.
Purchase: The water system purchases optimally fluoridated water from another public water system.

Fluoride Level: The fluoride level is provided for systems that do not adjust or purchase. Fluoride concentration is measured in parts per million (ppm) or milligrams per liter (mg/L).

Purchase From: The PWS ID indicated can be traced back to the original source of purchased water. The first two letters identify the state. The first two digits of the PWS ID identify the county in alphabetical order ([click](#) for a list of Ohio counties by code). The last five digits identify the system.

Please Note:

*Some water systems have fluoride levels tested at commercial labs that report levels of fluoride that are less than 0.5 ppm as "<0.5ppm." This is **NOT** specific enough for purposes of prescribing fluoride supplements. Health professionals should contact their local water plant in order to obtain more specific information on low fluoride levels.

**Public water systems comprise only a proportion of water systems that serve a county population. Some areas are served by non-community water systems.

The fluoride levels in the drinking water provided by public water systems which do not add supplemental fluoride are assumed to be the same as the natural fluoride content of the source water since typical water treatment or storage processes are not expected to remove fluoride.