

# Harrison County

## Ohio Public Water System Fluoride Levels, 2012



<u>PWS ID</u>	<u>Water System</u>	<u>Population Served</u>	<u>Fluoridation Status</u>	<u>Fluoride Level</u>	<u>Purchase From ID</u>	<u>Purchase From Name</u>
OH3400112	Bowerston Village PWS	517	Deficient	0.22		
OH3400214	Cadiz Village PWS	3,308	Adjusted			
OH3400312	Deersville Village PWS <sup>^</sup>	68	Deficient	0.22	OH3401612	Mwcd-Tappan Lake Park
OH3400412	Freeport Village PWS	455	Deficient	0.39		
OH3400503	Georgetown Water District	240	Purchase		OH3401403	Tri-County Water Authority
OH3400612	Germano Water And Sewer PWS	200	Deficient	0.20	OH3400912	Jewett Village
OH3400712	Harrison County Home	25	Deficient	0.26		
OH3400811	Hopedale Village PWS	984	Purchase		OH4101103	Jefferson Co. Water And Sewer District
OH3400912	Jewett Village	788	Deficient	0.21		
OH3401103	New Athens PWS	595	Purchase		OH0700412	Belmont Co. Sanitary District 3 PWS
OH3401212	Hcwsd-Piedmont PWS	154	Deficient	0.34		
OH3401312	Scio PWS	740	Deficient	0.46		
OH3401403	Tri-County Water Authority	2,286	Purchase		OH0701212	Martins Ferry Public Water System
OH3401503	Hcwsd-Unionvale-Kenwood PWS	384	Purchase		OH3400214	Cadiz Village PWS

<sup>^</sup> (3401612) Mwcd-Tappan Lake Park is a non-community water system that is not optimally fluoridated.

### How to use this table:

**Adjusted:** The natural fluoride level is adjusted to the optimum level for good dental health. [Click](#) for information about optimum fluoride levels.

**Deficient:** The natural fluoride level is below the optimum level for good dental health.

**Natural:** The fluoride level is naturally at optimum or higher levels.

**Purchase:** The water system purchases optimally fluoridated water from another public water system.

**Fluoride Level:** The fluoride level is provided for systems that do not adjust or purchase. Fluoride concentration is measured in parts per million (ppm) or milligrams per liter (mg/L).

**Purchase From:** The PWS ID indicated can be traced back to the original source of purchased water. The first two letters identify the state. The first two digits of the PWS ID identify the county in alphabetical order ([click](#) for a list of Ohio counties by code). The last five digits identify the system.

# Harrison County

---



## Ohio Public Water System Fluoride Levels, 2012

**Please Note:**

\*Some water systems have fluoride levels tested at commercial labs that report levels of fluoride that are less than 0.5 ppm as "<0.5ppm." This is NOT specific enough for purposes of prescribing fluoride supplements. Health professionals should contact their local water plant in order to obtain more specific information on low fluoride levels.

\*\*Public water systems comprise only a proportion of water systems that serve a county population. Some areas are served by non-community water systems.

*The fluoride levels in the drinking water provided by public water systems which do not add supplemental fluoride are assumed to be the same as the natural fluoride content of the source water since typical water treatment or storage processes are not expected to remove fluoride.*