

Lawrence County



Ohio Public Water System Fluoride Levels, 2012

<u>PWS ID</u>	<u>Water System</u>	<u>Population Served</u>	<u>Fluoridation Status</u>	<u>Fluoride Level</u>	<u>Purchase From ID</u>	<u>Purchase From Name</u>
OH4400012	Coal Grove PWS	2,027	Deficient	<0.20		
OH4400112	Ernies Mobile Home Park	196	Deficient	<0.10		
OH4400711	Ironton PWS	11,256	Adjusted			
OH4400803	Ohio American Water Co - Lawrence County [^]	9,481	Purchase		WV3300608	Wvaww- Huntington
OH4400912	Proctorville Village PWS	650	Deficient	<0.20		
OH4401212	South Point Village	3,831	Deficient	0.21		
OH4401612	Hecla Water Association-Plant PWS	29,848	Adjusted			
OH4402003	Lawrence Water Corp.	5,591	Purchase		OH4401612	Hecla Water Association-Plant PWS

[^] Ohio American Water Co - Lawrence County receives optimally fluoridated water from Wvaww-Huntington which is located in WV.

How to use this table:

Fluoridation Status: **Adjusted:** The natural fluoride level is adjusted to the optimum level for good dental health. [Click](#) for information about optimum fluoride levels.
Deficient: The natural fluoride level is below the optimum level for good dental health.
Natural: The fluoride level is naturally at optimum or higher levels.
Purchase: The water system purchases optimally fluoridated water from another public water system.

Fluoride Level: The fluoride level is provided for systems that do not adjust or purchase. Fluoride concentration is measured in parts per million (ppm) or milligrams per liter (mg/L).

Purchase From: The PWS ID indicated can be traced back to the original source of purchased water. The first two letters identify the state. The first two digits of the PWS ID identify the county in alphabetical order ([click](#) for a list of Ohio counties by code). The last five digits identify the system.

Please Note:

*Some water systems have fluoride levels tested at commercial labs that report levels of fluoride that are less than 0.5 ppm as "<0.5ppm." This is **NOT** specific enough for purposes of prescribing fluoride supplements. Health professionals should contact their local water plant in order to obtain more specific information on low fluoride levels.

**Public water systems comprise only a proportion of water systems that serve a county population. Some areas are served by non-community water systems.

The fluoride levels in the drinking water provided by public water systems which do not add supplemental fluoride are assumed to be the same as the natural fluoride content of the source water since typical water treatment or storage processes are not expected to remove fluoride.