

Mahoning County

Ohio Public Water System Fluoride Levels, 2012



<u>PWS ID</u>	<u>Water System</u>	<u>Population Served</u>	<u>Fluoridation Status</u>	<u>Fluoride Level</u>	<u>Purchase From ID</u>	<u>Purchase From Name</u>
OH5000411	Campbell City PWS	8,500	Adjusted			
OH5000503	Canfield City PWS	7,800	Purchase		OH5002303	Youngstown City PWS
OH5000612	Colonial Villa Estates^	350	Deficient	0.73		
OH5000912	M And C Mobile Home Park	55	Deficient	0.20		
OH5001212	Deer Meadow Estates	235	Deficient	0.23		
OH5001611	Aqua Ohio - Struthers	47,000	Adjusted			
OH5001812	Island Creek Homeowners	60	Natural	1.87		
OH5001911	Sebring Village PWS	8,100	Adjusted			
OH5002112	State Line MHP 2 PWS	35	Deficient	0.32		
OH5002303	Youngstown City PWS^^	148,000	Purchase		OH7801811	Mahoning Valley Sanitary District
OH5002812	State Line MHP 1 PWS	25	Deficient	0.31		
OH5003012	St. Marys Alzheimers Center	240	Deficient	0.22		
OH5054212	Jackson/Milton Service Area PWS	3,143	Purchase		OH5002303	Youngstown City PWS

^ Colonial Villa Estates has one well with optimal natural fluoridation

^^ (7801811) Mahoning Valley Sanitary District is a Non-Community water system that supplies optimally fluoridated water but does not appear on this list

How to use this table:

Adjusted: The natural fluoride level is adjusted to the optimum level for good dental health. [Click](#) for information about optimum fluoride levels.

Deficient: The natural fluoride level is below the optimum level for good dental health.

Natural: The fluoride level is naturally at optimum or higher levels.

Purchase: The water system purchases optimally fluoridated water from another public water system.

Fluoride Level: The fluoride level is provided for systems that do not adjust or purchase. Fluoride concentration is measured in parts per million (ppm) or milligrams per liter (mg/L).

Purchase From: The PWS ID indicated can be traced back to the original source of purchased water. The first two letters identify the state. The first two digits of the PWS ID identify the county in alphabetical order ([click](#) for a list of Ohio counties by code). The last five digits identify the system.

Mahoning County



Ohio Public Water System Fluoride Levels, 2012

Please Note:

*Some water systems have fluoride levels tested at commercial labs that report levels of fluoride that are less than 0.5 ppm as "<0.5ppm." This is NOT specific enough for purposes of prescribing fluoride supplements. Health professionals should contact their local water plant in order to obtain more specific information on low fluoride levels.

**Public water systems comprise only a proportion of water systems that serve a county population. Some areas are served by non-community water systems.

The fluoride levels in the drinking water provided by public water systems which do not add supplemental fluoride are assumed to be the same as the natural fluoride content of the source water since typical water treatment or storage processes are not expected to remove fluoride.