

Ottawa County

Ohio Public Water System Fluoride Levels, 2012



<u>PWS ID</u>	<u>Water System</u>	<u>Population Served</u>	<u>Fluoridation Status</u>	<u>Fluoride Level</u>	<u>Purchase From ID</u>	<u>Purchase From Name</u>
OH6200712	Elmore Village PWS	1,442	Natural	1.91		
OH6201003	Genoa Village PWS	2,800	Purchase		OH4800911	Oregon City PWS
OH6201212	Green Valley Mobile Home Park	40	Natural	1.83		
OH6201312	Greenwood Mobile Home Pk	174	Natural	0.95		
OH6202411	Marblehead Village PWS	725	Deficient	<0.20		
OH6202603	Oak Harbor Village PWS	4,432	Purchase		OH6205011	Ottawa County Regional
OH6203211	Port Clinton City PWS	6,391	Purchase		OH6205011	Ottawa County Regional
OH6203311	Put-In-Bay Village PWS	700	Deficient	0.13		
OH6204112	Allen Park Mobile Court	45	Natural	1.87		
OH6205011	Ottawa County Regional	14,885	Adjusted			
OH6205111	Carroll Water And Sewer	2,000	Deficient	<0.20		

How to use this table:

Fluoridation Status: **Adjusted:** The natural fluoride level is adjusted to the optimum level for good dental health. [Click](#) for information about optimum fluoride levels.
Deficient: The natural fluoride level is below the optimum level for good dental health.
Natural: The fluoride level is naturally at optimum or higher levels.
Purchase: The water system purchases optimally fluoridated water from another public water system.

Fluoride Level: The fluoride level is provided for systems that do not adjust or purchase. Fluoride concentration is measured in parts per million (ppm) or milligrams per liter (mg/L).

Purchase From: The PWS ID indicated can be traced back to the original source of purchased water. The first two letters identify the state. The first two digits of the PWS ID identify the county in alphabetical order ([click](#) for a list of Ohio counties by code). The last five digits identify the system.

Ottawa County



Ohio Public Water System Fluoride Levels, 2012

Please Note:

*Some water systems have fluoride levels tested at commercial labs that report levels of fluoride that are less than 0.5 ppm as "<0.5ppm." This is NOT specific enough for purposes of prescribing fluoride supplements. Health professionals should contact their local water plant in order to obtain more specific information on low fluoride levels.

**Public water systems comprise only a proportion of water systems that serve a county population. Some areas are served by non-community water systems.

The fluoride levels in the drinking water provided by public water systems which do not add supplemental fluoride are assumed to be the same as the natural fluoride content of the source water since typical water treatment or storage processes are not expected to remove fluoride.