

# Williams County



## Ohio Public Water System Fluoride Levels, 2012

<u>PWS ID</u>	<u>Water System</u>	<u>Population Served</u>	<u>Fluoridation Status</u>	<u>Fluoride Level</u>	<u>Purchase From ID</u>	<u>Purchase From Name</u>
OH8600012	Bryan Municipal Utilities	8,550	Natural	1.15		
OH8600312	Edgerton Village	2,117	Deficient	0.73		
OH8600512	Edon Village	980	Natural	0.96		
OH8600812	North Pine Estates	48	Natural	1.18		
OH8600912	Montpelier Village	4,320	Deficient	0.67		
OH8601012	Aqua Ohio - Norlick	345	Natural	1.10		
OH8601112	Northland Senior Community	50	Natural	1.03		
OH8601212	Oakwood MHP	180	Natural	1.10		
OH8601312	Pioneer Village	1,300	Natural	0.92		
OH8601512	Aqua Ohio - Seneca	750	Natural	1.03		
OH8601712	Stryker Village	1,468	Natural	1.23		
OH8601812	West Unity Village	1,790	Natural	1.00		
OH8601912	Williams Co/Hillside Country Living	109	Natural	1.12		

### How to use this table:

Fluoridation Status: **Adjusted:** The natural fluoride level is adjusted to the optimum level for good dental health. [Click](#) for information about optimum fluoride levels.  
**Deficient:** The natural fluoride level is below the optimum level for good dental health.  
**Natural:** The fluoride level is naturally at optimum or higher levels.  
**Purchase:** The water system purchases optimally fluoridated water from another public water system.

Fluoride Level: The fluoride level is provided for systems that do not adjust or purchase. Fluoride concentration is measured in parts per million (ppm) or milligrams per liter (mg/L).

Purchase From: The PWS ID indicated can be traced back to the original source of purchased water. The first two letters identify the state. The first two digits of the PWS ID identify the county in alphabetical order ([click](#) for a list of Ohio counties by code). The last five digits identify the system.

# Williams County

---



## Ohio Public Water System Fluoride Levels, 2012

**Please Note:**

\*Some water systems have fluoride levels tested at commercial labs that report levels of fluoride that are less than 0.5 ppm as "<0.5ppm." This is NOT specific enough for purposes of prescribing fluoride supplements. Health professionals should contact their local water plant in order to obtain more specific information on low fluoride levels.

\*\*Public water systems comprise only a proportion of water systems that serve a county population. Some areas are served by non-community water systems.

*The fluoride levels in the drinking water provided by public water systems which do not add supplemental fluoride are assumed to be the same as the natural fluoride content of the source water since typical water treatment or storage processes are not expected to remove fluoride.*