

Ashtabula County



Ohio Public Water System Fluoride Levels, 2012

<u>PWS ID</u>	<u>Water System</u>	<u>Population Served</u>	<u>Fluoridation Status</u>	<u>Fluoride Level</u>	<u>Purchase From ID</u>	<u>Purchase From Name</u>
OH0400012	Andover Village PWS	1,262	Deficient	0.17		
OH0400212	Camplands Water Company Llc	50	Deficient	0.14		
OH0400411	Conneaut City PWS	13,500	Adjusted			
OH0400512	Dfc Mobile Home Park	85	Deficient	0.59		
OH0400611	Roaming Shores Village PWS	1,300	Purchase		OH0400803	Ashtabula County Water System
OH0400711	Ohio American Water Co - Ashtabula	39,838	Adjusted			
OH0400803	Ashtabula County Water System	14,200	Purchase		OH0400711	Ohio American Water Co, Ashtabula
OH0401012	Orwell Village PWS	1,378	Deficient	0.27		
OH0401111	Rock Creek Village	550	Purchase		OH0400803	Ashtabula County Water System
OH0401212	Whispering Willow MHP PWS	193	Deficient	<0.50		
OH0401512	Austin Manor Mhc PWS	450	Purchase		OH0400803	Ashtabula County Water System
OH0401712	Geneva City PWS	7,000	Purchase		OH0400711	Ohio American Water Co, Ashtabula
OH0401812	Aqua Ohio - Village Of Jefferson	3,800	Purchase		OH0400711	Ohio American Water Co, Ashtabula

How to use this table:

Fluoridation Status: **Adjusted:** The natural fluoride level is adjusted to the optimum level for good dental health. [Click](#) for information about optimum fluoride levels.
Deficient: The natural fluoride level is below the optimum level for good dental health.
Natural: The fluoride level is naturally at optimum or higher levels.
Purchase: The water system purchases optimally fluoridated water from another public water system.

Fluoride Level: The fluoride level is provided for systems that do not adjust or purchase. Fluoride concentration is measured in parts per million (ppm) or milligrams per liter (mg/L).

Purchase From: The PWS ID indicated can be traced back to the original source of purchased water. The first two letters identify the state. The first two digits of the PWS ID identify the county in alphabetical order ([click](#) for a list of Ohio counties by code). The last five digits identify the system.

Ashtabula County



Ohio Public Water System Fluoride Levels, 2012

Please Note:

*Some water systems have fluoride levels tested at commercial labs that report levels of fluoride that are less than 0.5 ppm as "<0.5ppm." This is NOT specific enough for purposes of prescribing fluoride supplements. Health professionals should contact their local water plant in order to obtain more specific information on low fluoride levels.

**Public water systems comprise only a proportion of water systems that serve a county population. Some areas are served by non-community water systems.

The fluoride levels in the drinking water provided by public water systems which do not add supplemental fluoride are assumed to be the same as the natural fluoride content of the source water since typical water treatment or storage processes are not expected to remove fluoride.