

Columbiana County



Ohio Public Water System Fluoride Levels, 2012

<u>PWS ID</u>	<u>Water System</u>	<u>Population Served</u>	<u>Fluoridation Status</u>	<u>Fluoride Level</u>	<u>Purchase From ID</u>	<u>Purchase From Name</u>
OH1500112	Butler Mobile City	100	Deficient	0.31		
OH1500312	Columbiana City PWS	5,635	Adjusted			
OH1500811	East Liverpool City	13,089	Adjusted			
OH1500912	East Palestine City PWS	5,019	Adjusted			
OH1501212	Ivystone Water System	44	Deficient	<0.20		
OH1501412	Leetonia Village PWS	2,043	Purchase		OH1502011	Salem City
OH1501512	Lisbon Village	3,100	Deficient	0.22		
OH1501722	New Waterford Village PWS	1,487	Deficient	0.20		
OH1502011	Salem City	20,035	Adjusted			
OH1502512	Tomahawk Utilities, Inc.	500	Deficient	0.30		
OH1502612	Town And Country Estates	39	Deficient	0.14		
OH1502712	Pleasant View North Retirement Ctr	65	Deficient	0.19		
OH1502812	Washingtonville Village PWS	890	Purchase		OH1502011	Salem City
OH1502911	Buckeye Water District - Ohio River	10,175	Adjusted			
OH1503012	Winona Water Supply	100	Deficient	0.22		
OH1503312	Farr Hill MHP	100	Deficient	0.24		
OH1503412	Guilford Lake Estates	125	Natural	0.82		
OH1503512	Breezeway Mobile Manor	46	Deficient	0.19		
OH1503712	Columbiana County Jail PWS^	173	Deficient	0.44		
OH1504112	Guilford Highlands Mobile Home Park PWS	88	Deficient	0.29		

^ Columbiana County Jail fluoride levels fluctuate but remain deficient

Columbiana County



Ohio Public Water System Fluoride Levels, 2012

How to use this table:

Fluoridation Status: **Adjusted:** The natural fluoride level is adjusted to the optimum level for good dental health. [Click](#) for information about optimum fluoride levels.
Deficient: The natural fluoride level is below the optimum level for good dental health.
Natural: The fluoride level is naturally at optimum or higher levels.
Purchase: The water system purchases optimally fluoridated water from another public water system.

Fluoride Level: The fluoride level is provided for systems that do not adjust or purchase. Fluoride concentration is measured in parts per million (ppm) or milligrams per liter (mg/L).

Purchase From: The PWS ID indicated can be traced back to the original source of purchased water. The first two letters identify the state. The first two digits of the PWS ID identify the county in alphabetical order ([click](#) for a list of Ohio counties by code). The last five digits identify the system.

Please Note:

*Some water systems have fluoride levels tested at commercial labs that report levels of fluoride that are less than 0.5 ppm as "<0.5ppm." This is **NOT** specific enough for purposes of prescribing fluoride supplements. Health professionals should contact their local water plant in order to obtain more specific information on low fluoride levels.

**Public water systems comprise only a proportion of water systems that serve a county population. Some areas are served by non-community water systems.

The fluoride levels in the drinking water provided by public water systems which do not add supplemental fluoride are assumed to be the same as the natural fluoride content of the source water since typical water treatment or storage processes are not expected to remove fluoride.