

Hancock County



Ohio Public Water System Fluoride Levels, 2012

<u>PWS ID</u>	<u>Water System</u>	<u>Population Served</u>	<u>Fluoridation Status</u>	<u>Fluoride Level</u>	<u>Purchase From ID</u>	<u>Purchase From Name</u>
OH3200012	Arlington Village Water	1,500	Natural	1.51		
OH3200111	Findlay Water Treatment Plant	40,000	Adjusted			
OH3200411	Mccomb Water Treatment Plant	1,700	Adjusted			
OH3200512	Mt Blanchard Village	481	Natural	1.17		
OH3200612	Rawson Water Treatment Plant	480	Natural	1.49		
OH3200812	Green Meadow MHP-Hancock Co	32	Natural	1.54		
OH3200903	Arcadia Water Pumping Station	545	Purchase		OH7400411	Fostoria City
OH3248312	Vanlue Village Water	371	Natural	1.11		

How to use this table:

Fluoridation Status: **Adjusted:** The natural fluoride level is adjusted to the optimum level for good dental health. [Click](#) for information about optimum fluoride levels.
Deficient: The natural fluoride level is below the optimum level for good dental health.
Natural: The fluoride level is naturally at optimum or higher levels.
Purchase: The water system purchases optimally fluoridated water from another public water system.

Fluoride Level: The fluoride level is provided for systems that do not adjust or purchase. Fluoride concentration is measured in parts per million (ppm) or milligrams per liter (mg/L).

Purchase From: The PWS ID indicated can be traced back to the original source of purchased water. The first two letters identify the state. The first two digits of the PWS ID identify the county in alphabetical order ([click](#) for a list of Ohio counties by code). The last five digits identify the system.

Please Note:

*Some water systems have fluoride levels tested at commercial labs that report levels of fluoride that are less than 0.5 ppm as "<0.5ppm." This is **NOT** specific enough for purposes of prescribing fluoride supplements. Health professionals should contact their local water plant in order to obtain more specific information on low fluoride levels.

**Public water systems comprise only a proportion of water systems that serve a county population. Some areas are served by non-community water systems.

The fluoride levels in the drinking water provided by public water systems which do not add supplemental fluoride are assumed to be the same as the natural fluoride content of the source water since typical water treatment or storage processes are not expected to remove fluoride.