

Holmes County



Ohio Public Water System Fluoride Levels, 2012

<u>PWS ID</u>	<u>Water System</u>	<u>Population Served</u>	<u>Fluoridation Status</u>	<u>Fluoride Level</u>	<u>Purchase From ID</u>	<u>Purchase From Name</u>
OH3800012	Berlin Water Company	2,400	Deficient	0.37		
OH3800112	Big Prairie Water Co.	200	Deficient	0.25		
OH3800312	Glenmont Village PWS	240	Deficient	0.20		
OH3800412	Hilltop Group Home Inc. PWS	30	Deficient	0.43		
OH3800512	Holmes County Jail	156	Deficient	<0.20		
OH3800712	Killbuck Village PWS	900	Deficient	0.19		
OH3800812	Bloomfield Water Company	950	Deficient	0.23		
OH3800912	Millersburg Village PWS	3,025	Deficient	<0.20		
OH3801012	Nashville Village PWS	172	Deficient	0.31		
OH3801112	Castle Nursing Homes, Inc PWS	510	Deficient	<0.20		
OH3801412	Winesburg Area Development Corporation	1,150	Deficient	0.25		
OH3801512	Walnut Creek Water Co.	1,400	Deficient	0.46		

How to use this table:

Fluoridation Status: **Adjusted:** The natural fluoride level is adjusted to the optimum level for good dental health. [Click](#) for information about optimum fluoride levels. **Deficient:** The natural fluoride level is below the optimum level for good dental health.

Natural: The fluoride level is naturally at optimum or higher levels.

Purchase: The water system purchases optimally fluoridated water from another public water system.

Fluoride Level: The fluoride level is provided for systems that do not adjust or purchase. Fluoride concentration is measured in parts per million (ppm) or milligrams per liter (mg/L).

Purchase From: The PWS ID indicated can be traced back to the original source of purchased water. The first two letters identify the state. The first two digits of the PWS ID identify the county in alphabetical order ([click](#) for a list of Ohio counties by code). The last five digits identify the system.

Holmes County



Ohio Public Water System Fluoride Levels, 2012

Please Note:

*Some water systems have fluoride levels tested at commercial labs that report levels of fluoride that are less than 0.5 ppm as "<0.5ppm." This is NOT specific enough for purposes of prescribing fluoride supplements. Health professionals should contact their local water plant in order to obtain more specific information on low fluoride levels.

**Public water systems comprise only a proportion of water systems that serve a county population. Some areas are served by non-community water systems.

The fluoride levels in the drinking water provided by public water systems which do not add supplemental fluoride are assumed to be the same as the natural fluoride content of the source water since typical water treatment or storage processes are not expected to remove fluoride.