

# Jefferson County

## Ohio Public Water System Fluoride Levels, 2012



<u>PWS ID</u>	<u>Water System</u>	<u>Population Served</u>	<u>Fluoridation Status</u>	<u>Fluoride Level</u>	<u>Purchase From ID</u>	<u>Purchase From Name</u>
OH410003	Adena Village PWS	950	Purchase		OH3401403	Tri-County Water Authority
OH4100412	Brilliant Water And Sewer	1,762	Deficient	<0.20		
OH4100512	Dillonvale	997	Deficient	0.75		
OH4100803	Jefferson Co. W&S District- A	2,707	Deficient	<0.20	OH4100412	Brilliant Water & Sewer
OH4101003	Jefferson Co W&S District- J	896	Purchase		OH4102411	Steubenville, City Of
OH4101103	Jefferson Co W And S District - M	14,795	Purchase		OH4102811	Toronto PWS
OH4101203	Jefferson Co W&S District- O	420	Purchase		OH4102411	Steubenville, City Of
OH4101303	Jefferson Co W&S District- Piney	431	Deficient	<0.20	OH4102312	Smithfield Village PWS
OH4101612	Mingo Junction PWS	3,472	Adjusted			
OH4101712	Mount Pleasant PWS	550	Deficient	<0.20		
OH4101803	Rayland Village PWS	434	Deficient	0.22	OH4102712	Tiltonsville PWS
OH4102012	Richmond Village PWS	464	Purchase		OH4101103	Jefferson Co. Water And Sewer District
OH4102312	Smithfield PWS	1,223	Deficient	<0.20	OH4100803	Jefferson Co. Water And Sewer District-
OH4102411	Steubenville, City Of	19,002	Adjusted			
OH4102512	Stratton PWS	300	Deficient	0.38		
OH4102712	Tiltonsville PWS	1,820	Deficient	0.22		
OH4102811	Toronto PWS	5,600	Adjusted			
OH4102903	Warren Water Authority	484	Deficient	0.50	OH4103112	Yorkville Village PWS
OH4103003	Wintersville Village PWS	4,067	Purchase		OH4101103	Jefferson Co. Water And Sewer District
OH4103112	Yorkville Village PWS	1,554	Deficient	0.31	OH4102712	Tiltonsville PWS

# Jefferson County



## Ohio Public Water System Fluoride Levels, 2012

### How to use this table:

Fluoridation Status: **Adjusted:** The natural fluoride level is adjusted to the optimum level for good dental health. [Click](#) for information about optimum fluoride levels.  
**Deficient:** The natural fluoride level is below the optimum level for good dental health.  
**Natural:** The fluoride level is naturally at optimum or higher levels.  
**Purchase:** The water system purchases optimally fluoridated water from another public water system.

Fluoride Level: The fluoride level is provided for systems that do not adjust or purchase. Fluoride concentration is measured in parts per million (ppm) or milligrams per liter (mg/L).

Purchase From: The PWS ID indicated can be traced back to the original source of purchased water. The first two letters identify the state. The first two digits of the PWS ID identify the county in alphabetical order ([click](#) for a list of Ohio counties by code). The last five digits identify the system.

### Please Note:

\*Some water systems have fluoride levels tested at commercial labs that report levels of fluoride that are less than 0.5 ppm as "<0.5ppm." This is NOT specific enough for purposes of prescribing fluoride supplements. Health professionals should contact their local water plant in order to obtain more specific information on low fluoride levels.

\*\*Public water systems comprise only a proportion of water systems that serve a county population. Some areas are served by non-community water systems.

*The fluoride levels in the drinking water provided by public water systems which do not add supplemental fluoride are assumed to be the same as the natural fluoride content of the source water since typical water treatment or storage processes are not expected to remove fluoride.*