

Licking County

Ohio Public Water System Fluoride Levels, 2012



<u>PWS ID</u>	<u>Water System</u>	<u>Population Served</u>	<u>Fluoridation Status</u>	<u>Fluoride Level</u>	<u>Purchase From ID</u>	<u>Purchase From Name</u>
OH4500212	Lakeshore Court Mobile Home	85	Natural	1.11		
OH4500312	Country Hills MHP	48	Deficient	0.10		
OH4500512	El Rancho Mobile Home Park	57	Deficient	0.20		
OH4500612	Granville, Village Of	5,167	Adjusted			
OH4500712	Green Meadows MHP	50	Natural	0.99		
OH4500812	Licking County Harbor Hills PWS	938	Purchase		OH4501012	Hebron Village PWS
OH4500912	City Of Heath PWS	9,000	Adjusted			
OH4501012	Hebron Village PWS	2,200	Adjusted			
OH4501512	Johnstown Village PWS	4,200	Deficient	0.58		
OH4501712	Licking County Prescott Estates	425	Deficient	0.50		
OH4502314	Newark City PWS	48,000	Adjusted			
OH4502512	Pataskala City	8,150	Natural	1.23		
OH4502812	Suburban Mobile Home Park	53	Deficient	0.20		
OH4503012	Utica Village PWS	2,250	Deficient	0.38		
OH4503112	Valley Mobile Home Park	88	Deficient	0.28		
OH4503312	Wilkins Mobile Home Park	115	Deficient	0.17		
OH4504012	St Louisville Village PWS	386	Deficient	0.20		
OH4504203	Alexandria Village PWS	479	Purchase		OH4500612	Granville, Village Of
OH4504312	Villa Vista Mobile Home	173	Deficient	0.38		
OH4504612	Pine Kirk Care Center	46	Natural	1.02		
OH4505412	Southwest Licking Community Water	12,088	Adjusted			
OH4505512	Leisure Village MHP 2 PWS	517	Natural	1.37		
OH4564712	Buckeye Lake, Village Of PWS	3,000	Purchase		OH2301212	Millersport Village PWS

Licking County



Ohio Public Water System Fluoride Levels, 2012

<u>PWS ID</u>	<u>Water System</u>	<u>Population Served</u>	<u>Fluoridation Status</u>	<u>Fluoride Level</u>	<u>Purchase From ID</u>	<u>Purchase From Name</u>
OH4566012	Gratiot Improvement Association	36	Deficient	<0.50		
OH4566112	East End Water Co	32	Deficient	<0.50		

How to use this table:

Fluoridation Status: **Adjusted:** The natural fluoride level is adjusted to the optimum level for good dental health. [Click](#) for information about optimum fluoride levels.
Deficient: The natural fluoride level is below the optimum level for good dental health.
Natural: The fluoride level is naturally at optimum or higher levels.
Purchase: The water system purchases optimally fluoridated water from another public water system.

Fluoride Level: The fluoride level is provided for systems that do not adjust or purchase. Fluoride concentration is measured in parts per million (ppm) or milligrams per liter (mg/L).

Purchase From: The PWS ID indicated can be traced back to the original source of purchased water. The first two letters identify the state. The first two digits of the PWS ID identify the county in alphabetical order ([click](#) for a list of Ohio counties by code). The last five digits identify the system.

Please Note:

*Some water systems have fluoride levels tested at commercial labs that report levels of fluoride that are less than 0.5 ppm as "<0.5ppm." This is **NOT** specific enough for purposes of prescribing fluoride supplements. Health professionals should contact their local water plant in order to obtain more specific information on low fluoride levels.

**Public water systems comprise only a proportion of water systems that serve a county population. Some areas are served by non-community water systems.

The fluoride levels in the drinking water provided by public water systems which do not add supplemental fluoride are assumed to be the same as the natural fluoride content of the source water since typical water treatment or storage processes are not expected to remove fluoride.