

Logan County



Ohio Public Water System Fluoride Levels, 2012

<u>PWS ID</u>	<u>Water System</u>	<u>Population Served</u>	<u>Fluoridation Status</u>	<u>Fluoride Level</u>	<u>Purchase From ID</u>	<u>Purchase From Name</u>
OH4600012	Belle Center Village PWS	834	Natural	1.04		
OH4600112	Bellefontaine City PWS	13,069	Adjusted			
OH4600312	Whispering Valley MHP	75	Natural	1.47		
OH4600512	Degraff Village PWS	1,215	Deficient	0.74		
OH4600812	Holiday Shores MHP PWS	115	Natural	1.54		
OH4601012	Indian Hill Mobile Home	65	Deficient	0.71		
OH4601112	Heartland Of Indian Lake - Nc	25	Natural	1.71		
OH4601312	Lakeridge Resorts, Inc. MHP	40	Natural	1.46		
OH4601412	Lakeside Court MHP PWS	80	Natural	1.43		
OH4601512	Lakeview Village PWS	1,250	Natural	1.13		
OH4601912	Quincy Village PWS	753	Natural	0.90		
OH4602012	Mountainview Mobile Village	194	Deficient	0.56		
OH4602112	Rushsylvania Village PWS	555	Natural	1.24		
OH4602212	Russells Point Village PWS	1,651	Deficient	0.61		
OH4602412	West Liberty Village PWS	1,800	Deficient	0.26		
OH4602512	West Mansfield Village PWS	810	Natural	1.95		
OH4602612	Heartland Of Indian Lake - Rc	51	Natural	1.79		
OH4602712	Tammis Mobile Village Ltd. PWS	98	Deficient	0.19		
OH4634612	Cottonwood Enterprises	20	Natural	1.29		

Logan County



Ohio Public Water System Fluoride Levels, 2012

How to use this table:

Fluoridation Status: **Adjusted:** The natural fluoride level is adjusted to the optimum level for good dental health. [Click](#) for information about optimum fluoride levels.
Deficient: The natural fluoride level is below the optimum level for good dental health.
Natural: The fluoride level is naturally at optimum or higher levels.
Purchase: The water system purchases optimally fluoridated water from another public water system.

Fluoride Level: The fluoride level is provided for systems that do not adjust or purchase. Fluoride concentration is measured in parts per million (ppm) or milligrams per liter (mg/L).

Purchase From: The PWS ID indicated can be traced back to the original source of purchased water. The first two letters identify the state. The first two digits of the PWS ID identify the county in alphabetical order ([click](#) for a list of Ohio counties by code). The last five digits identify the system.

Please Note:

*Some water systems have fluoride levels tested at commercial labs that report levels of fluoride that are less than 0.5 ppm as "<0.5ppm." This is NOT specific enough for purposes of prescribing fluoride supplements. Health professionals should contact their local water plant in order to obtain more specific information on low fluoride levels.

**Public water systems comprise only a proportion of water systems that serve a county population. Some areas are served by non-community water systems.

The fluoride levels in the drinking water provided by public water systems which do not add supplemental fluoride are assumed to be the same as the natural fluoride content of the source water since typical water treatment or storage processes are not expected to remove fluoride.