

Putnam County



Ohio Public Water System Fluoride Levels, 2012

<u>PWS ID</u>	<u>Water System</u>	<u>Population Served</u>	<u>Fluoridation Status</u>	<u>Fluoride Level</u>	<u>Purchase From ID</u>	<u>Purchase From Name</u>
OH6900112	Columbus Grove Water	2,200	Natural	1.04		
OH6900212	Continental Village Water	1,200	Natural	2.09		
OH6900512	Kalida Village Water	1,075	Natural	1.12		
OH6900612	Leipsic Village Water	2,236	Natural	2.23		
OH6900711	Ottawa Village Water	4,367	Adjusted			
OH6900812	Ottoville Village Water	900	Natural	1.46		
OH6900912	Pandora Village Water	1,200	Natural	1.32		
OH6901303	Glandorf Village Water	975	Purchase		OH6900711	Ottawa Water Treatment Plant
OH6901412	Country Acres Golf Club	190	Natural	1.41		
OH6901503	Putnam County-East Ottawa	225	Purchase		OH6900711	Ottawa Water Treatment Plant
OH6901603	Putnam County-North Ottawa	343	Purchase		OH6900711	Ottawa Water Treatment Plant

How to use this table:

Fluoridation Status: **Adjusted:** The natural fluoride level is adjusted to the optimum level for good dental health. [Click](#) for information about optimum fluoride levels.
Deficient: The natural fluoride level is below the optimum level for good dental health.
Natural: The fluoride level is naturally at optimum or higher levels.
Purchase: The water system purchases optimally fluoridated water from another public water system.

Fluoride Level: The fluoride level is provided for systems that do not adjust or purchase. Fluoride concentration is measured in parts per million (ppm) or milligrams per liter (mg/L).

Purchase From: The PWS ID indicated can be traced back to the original source of purchased water. The first two letters identify the state. The first two digits of the PWS ID identify the county in alphabetical order ([click](#) for a list of Ohio counties by code). The last five digits identify the system.

Putnam County



Ohio Public Water System Fluoride Levels, 2012

Please Note:

*Some water systems have fluoride levels tested at commercial labs that report levels of fluoride that are less than 0.5 ppm as "<0.5ppm." This is NOT specific enough for purposes of prescribing fluoride supplements. Health professionals should contact their local water plant in order to obtain more specific information on low fluoride levels.

**Public water systems comprise only a proportion of water systems that serve a county population. Some areas are served by non-community water systems.

The fluoride levels in the drinking water provided by public water systems which do not add supplemental fluoride are assumed to be the same as the natural fluoride content of the source water since typical water treatment or storage processes are not expected to remove fluoride.