

Scioto County



Ohio Public Water System Fluoride Levels, 2012

<u>PWS ID</u>	<u>Water System</u>	<u>Population Served</u>	<u>Fluoridation Status</u>	<u>Fluoride Level</u>	<u>Purchase From ID</u>	<u>Purchase From Name</u>
OH7300003	Northwest Regional Water District	13,009	Purchase		OH7300212	Scioto Co. Regional Water District #1
OH7300111	Portsmouth Public Water System	38,973	Adjusted			
OH7300212	Scioto Co. Regional Water District #1	13,876	Adjusted			
OH7300303	Scioto Water, Inc.-Rose Hill	10,001	Adjusted			
OH7300803	Scioto Water, Inc.-Stony Run	179	Purchase		OH7300111	Portsmouth, City Of
OH7300903	Scioto Water, Inc.-Sugar Camp	8,481	Purchase		OH7300111	Portsmouth, City Of
OH7301203	Scioto Water, Inc.-Sr125	672	Purchase		OH7300111	Portsmouth, City Of
OH7301303	Scioto Water, Inc.-Pond Run	988	Purchase		OH7300111	Portsmouth, City Of
OH7301503	Scioto Water, Inc.-Zeigler Lane	81	Purchase		OH7300111	Portsmouth, City Of
OH7301603	Scioto Water, Inc.-Slab Run	125	Purchase		OH7300111	Portsmouth, City Of
OH7301703	Scioto Water, Inc.-Careys Run	375	Purchase		OH7300111	Portsmouth, City Of
OH7301903	Scioto Water Inc.- Hygean Run	59	Purchase		OH7300111	Portsmouth, City Of
OH7302103	Scioto Water, Inc.- Naces Run	67	Purchase		OH7300111	Portsmouth, City Of
OH7302203	Scioto Water, Inc.-Oakwood	36	Purchase		OH7300111	Portsmouth, City Of
OH7302403	Scioto Water Inc-Sheila Blvd	36	Purchase		OH7300111	Portsmouth, City Of
OH7302503	Scioto Water, Inc.-Davis Camp	98	Purchase		OH7300212	Scioto Co. Regional Water District #1

How to use this table:

Fluoridation Status: **Adjusted:** The natural fluoride level is adjusted to the optimum level for good dental health. [Click](#) for information about optimum fluoride levels.
Deficient: The natural fluoride level is below the optimum level for good dental health.
Natural: The fluoride level is naturally at optimum or higher levels.
Purchase: The water system purchases optimally fluoridated water from another public water system.

Fluoride Level: The fluoride level is provided for systems that do not adjust or purchase. Fluoride concentration is measured in parts per million (ppm) or milligrams per liter (mg/L).

Purchase From: The PWS ID indicated can be traced back to the original source of purchased water. The first two letters identify the state. The first two digits of the PWS ID identify the county in alphabetical order ([click](#) for a list of Ohio counties by code). The last five digits identify the system.

Scioto County



Ohio Public Water System Fluoride Levels, 2012

Please Note:

*Some water systems have fluoride levels tested at commercial labs that report levels of fluoride that are less than 0.5 ppm as "<0.5ppm." This is NOT specific enough for purposes of prescribing fluoride supplements. Health professionals should contact their local water plant in order to obtain more specific information on low fluoride levels.

**Public water systems comprise only a proportion of water systems that serve a county population. Some areas are served by non-community water systems.

The fluoride levels in the drinking water provided by public water systems which do not add supplemental fluoride are assumed to be the same as the natural fluoride content of the source water since typical water treatment or storage processes are not expected to remove fluoride.