

Seneca County



Ohio Public Water System Fluoride Levels, 2012

<u>PWS ID</u>	<u>Water System</u>	<u>Population Served</u>	<u>Fluoridation Status</u>	<u>Fluoride Level</u>	<u>Purchase From ID</u>	<u>Purchase From Name</u>
OH7400011	Attica Village	955	Adjusted			
OH7400112	Bettsville Village	900	Natural	1.38		
OH7400212	Bloomville Village PWS	1,045	Natural	1.34		
OH7400411	Fostoria City	15,062	Adjusted			
OH7400512	Green Springs Village PWS	1,247	Purchase		OH7200211	Clyde Water Treatment Plant
OH7400614	Ohio American Water Co-Tiffin District	18,300	Adjusted			
OH7400712	Fostoria Mobile Estates	88	Deficient	0.37		
OH7400812	Republic Village	610	Deficient	0.75		
OH7400912	Ruffing Family Care Center	99	Natural	0.92		
OH7401212	Poplar Village MHP	175	Natural	1.65		
OH7401312	Brook Park Estates MHP PWS	90	Natural	1.98		
OH7401412	Hopewell Estates MHP	125	Deficient	0.66		

How to use this table:

Fluoridation Status: **Adjusted:** The natural fluoride level is adjusted to the optimum level for good dental health. [Click](#) for information about optimum fluoride levels.
Deficient: The natural fluoride level is below the optimum level for good dental health.

Natural: The fluoride level is naturally at optimum or higher levels.

Purchase: The water system purchases optimally fluoridated water from another public water system.

Fluoride Level: The fluoride level is provided for systems that do not adjust or purchase. Fluoride concentration is measured in parts per million (ppm) or milligrams per liter (mg/L).

Purchase From: The PWS ID indicated can be traced back to the original source of purchased water. The first two letters identify the state. The first two digits of the PWS ID identify the county in alphabetical order ([click](#) for a list of Ohio counties by code). The last five digits identify the system.

Seneca County



Ohio Public Water System Fluoride Levels, 2012

Please Note:

*Some water systems have fluoride levels tested at commercial labs that report levels of fluoride that are less than 0.5 ppm as "<0.5ppm." This is NOT specific enough for purposes of prescribing fluoride supplements. Health professionals should contact their local water plant in order to obtain more specific information on low fluoride levels.

**Public water systems comprise only a proportion of water systems that serve a county population. Some areas are served by non-community water systems.

The fluoride levels in the drinking water provided by public water systems which do not add supplemental fluoride are assumed to be the same as the natural fluoride content of the source water since typical water treatment or storage processes are not expected to remove fluoride.