

3701:1-52-10      **Fire protection.**

- (A) The radiation room at a panoramic irradiator must have heat and smoke detectors. The detectors must activate an audible alarm. The alarm must be capable of alerting a person who is prepared to summon assistance promptly. The sources must automatically become fully shielded if a fire is detected.
- (B) The radiation room at a panoramic irradiator must be equipped with a fire extinguishing system capable of extinguishing a fire without the entry of personnel into the room. The system for the radiation room must have a shut-off valve to control flooding into unrestricted areas.

Five Year Review (FYR) Dates:                      10/25/2016 and 10/15/2021

CERTIFIED ELECTRONICALLY

\_\_\_\_\_  
Certification

10/25/2016

\_\_\_\_\_  
Date

Promulgated Under:            119.03  
Statutory Authority:           3748.04  
Rule Amplifies:                3748.04  
Prior Effective Dates:        10/20/2002