

3701:1-52-16 Design requirements.

Irradiators whose construction begins after July 1, 1993, must meet the design requirements of this rule.

- (A) For all irradiators, the licensee shall evaluate the location and sensitivity of the monitor to detect sources carried by the product conveyor system as required by paragraph (A) of rule 3701:1-52-11 of the Administrative Code. The licensee shall verify that the product conveyor is designed to stop before a source on the product conveyor would cause a radiation overexposure to any person.
- (B) For panoramic irradiators the licensee shall:
 - (1) Design shielding walls to meet generally accepted building code requirements for reinforced concrete and design the walls, wall penetrations, and entranceways to meet the radiation shielding requirements of rule 3701:1-52-09 of the Administrative Code. If the irradiator will use more than 2×10^{17} becquerels (five million curies) of activity, evaluate the effects of heating of the shielding walls by the irradiator sources;
 - (2) Design the foundation, with consideration given to soil characteristics, to ensure it is adequate to support the weight of the facility shield walls;
 - (3) Verify from the design and logic diagram that the access control system will meet the requirements of rule 3701:1-52-08 of the Administrative Code;
 - (4) Verify that the number, location, and spacing of the smoke and heat detectors are appropriate to detect fires and that the detectors are protected from mechanical and radiation damage, and verify that the design of the fire extinguishing system provides the necessary discharge patterns, densities, and flow characteristics for complete coverage of the radiation room and that the system is protected from mechanical and radiation damage;
 - (5) Verify that the source rack will automatically return to the fully shielded position if offsite power is lost for more than ten seconds;
 - (6) If to be built in seismic areas, the licensee shall design the reinforced concrete radiation shields to retain their integrity in the event of an earthquake by designing to the seismic requirements of an appropriate source such as American Concrete Institute Standard ACI 318-89, "Building Code Requirements for Reinforced Concrete," Chapter 21, "Special Provisions for Seismic Design," revised 1992 (this publication may be obtained from the American Concrete Institute, PO Box 9094, Farmington Hills, MI 48331, telephone (248)848-3700, <http://www.concrete.org/store.aspx>) or local building codes, if current;
 - (7) Verify that electrical wiring and electrical equipment in the radiation room are selected to minimize failures due to prolonged exposure to radiation.
 - (8) Determine that source rack drops due to loss of power will not damage the source rack and that source rack drops due to failure of cables (or alternate means of support) will not cause loss of integrity of sealed sources; and
 - (9) Review the design of the mechanism that moves the sources to assure that the

likelihood of a stuck source is low and that, if the rack sticks, a means exists to free it with minimal risk to personnel.

(C) For pool irradiators the licensee shall:

- (1) Design the pool to assure that it is leak resistant, that it is strong enough to bear the weight of the pool water and shipping casks, that a dropped cask would not fall on sealed sources, that all outlets or pipes meet the requirements of paragraph (B) of rule 3701:1-52-13 of the Administrative Code, and that metal components are metallurgically compatible with other components in the pool;
- (2) Verify that the design of the water purification system is adequate to meet the requirements of paragraph (E) of rule 3701:1-52-13 of the Administrative Code. The system must be designed so that water leaking from the system does not drain to unrestricted areas without being monitored;
- (3) Verify that there are no crevices on the source or between the source and source holder that would promote corrosion on a critical area of the source; and
- (4) If the licensee uses radiation monitors to detect contamination under paragraph (B) of rule 3701:1-52-22 of the Administrative Code, the licensee shall verify that the design of radiation monitoring systems to detect pool contamination includes sensitive detectors located close to where contamination is likely to concentrate.

Effective: 01/15/2017

R.C. 119.032 review dates: 10/31/2016 and 10/15/2021

CERTIFIED ELECTRONICALLY
Certification

01/05/2017

Date

Promulgated Under: 119.03
Statutory Authority: 3748.04
Rule Amplifies: 3748.04
Prior Effective Dates: 10/20/2002, 10/8/07, 9/1/12