

3717-1-08.3 Special requirements: bulk water machine criteria.

[Comment: For publication dates of the C.F.R. referenced in this rule, see paragraph (B)(15)(b) of rule 3717-1-01 of the Administrative Code.]

- (A) Water dispensed from a bulk water machine shall meet the quality standards specified in 21 C.F.R. 165, Subpart B.
- (B) Bulk water machines shall be connected to an approved water supply.
- (C) Bulk water machines shall be in compliance with the construction and performance standards set forth in paragraph (KK) of rule 3717-1-04.1 of the Administrative Code and shall be maintained to those standards.
- (D) All water processed through a bulk water machine shall be disinfected as the last treatment step prior to being dispensed.
- (E) Bulk water machines shall be equipped with monitoring devices designed to shut down operation of the machine when the disinfection unit fails to function.
- (F) Bulk water machines shall be maintained in a clean and sanitary condition.
- (G) Bulk water machines shall be located in an area that can be maintained in a clean condition and in a manner that avoids insect and rodent harborage.
- (H) The water dispensed from bulk water machines shall be sampled at least semi-annually for coliform bacteria. Sample results shall be retained at the food service operation or retail food establishment for review by the licensor.

Effective: 01/01/2013

R.C. 119.032 review dates: 05/25/2012 and 12/01/2017

CERTIFIED ELECTRONICALLY

Certification

08/31/2012

Date

Promulgated Under: 119.03
Statutory Authority: 3717.04, 3717.05
Rule Amplifies: 3717.04, 3717.05
Prior Effective Dates: 3/1/2001, 3/1/09